

Our Ref: HL/M130434
Test Report: MAT/LAB 653E



4th February 2013

Keramo SpA.
Via Also Galli 55,
22038 Tavernerio (CO),
Italy

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

CERAMIC

5023

Kersic 1000. Grey coloured, compression moulded silicon carbide ring. For use with water up to 85°C.

APPROVAL NUMBER: 1301533

APPROVAL HOLDER: KERAMO SPA.

The Scheme reserves the right to review approval. This approval is valid between January 2013 and January 2018.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written over a light blue horizontal line.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme